

Er. P. ARUN PRASAD

B.Tech., M.I.E., F.I.V., M.I.C.A., M.I.S.T.E., M.ACCE.,

- Registered **PWD APPROVED ENGINEER**
No. AEE/TI/AE/48411/2015 Dt:3.11.2015
PWD - Chopauk - Chennai, Govt of Tamil Nadu
- Coimbatore **DISTRICT COLLECTOR'S PANEL ENGINEER**
Tamil Nadu Public Building (Licensing) Act - 1965
Reg No.1 /12016/C2, Govt of Tamil Nadu
- Chartered Civil Engineer & Approved Valuer
Structural Consultant & Arbitrator
Licensed Building Surveyor & Consulting Civil Engineer

ARUN ASSOCIATES

Engineers & Valuers

10/33, Ayyappan Kovil Street,
Venkatesa Colony,
Pollachi - 642 001.
Coimbatore Dist.
Tamil Nadu.
Cell : 98653 39919
Off : 90950 12031
Mail ID : arunassociates93@gmail.com

DECLARATION

I P.Arun Prasad, Office at Arun Associates, 10/33 Ayappan Kovil Street, Venkatesa Colony, Pollachi – 642001 to hereby declare that I Possess the qualification and experience specified in the Table to ruel 11 of the Madras Public Building (Licensing) Rules 1966 for issuing the certificate of structural soundness of the Building covered by the certificate.

Station: Pollachi


Date: 25.03.2023

Signature of the Certifying Engineer



Er. P. ARUN PRASAD, B.Tech., C.Engg.,
M.I.E., F.I.V., M.I.C.A., M.ACCE.,
Approved Valuer, Consulting Civil Engineer & L.B.S.,
10/33, Ayyappan Kovil Street, Venkatesa Colony,
Pollachi - 642 001 Cell 98653 39919
COIMBATORE DISTRICT COLLECTOR'S
PANEL ENGINEER
GOVERNMENT OF TAMILNADU

1. Name and address of the Collectors panel Engineer : Er.P. Aun Prasad
10/33 Ayyappan Kovil Street,
Venkatesa Colony
Pollachi.
Cell: 98653 – 39919
2. Engineering Qualification : B.Tech. Civil, M.I.E., F.I.V., M.I.C.A., M.ACCE.,
Chartered Civil Engineer (Ind) M-150099-0
Approved Valuer F – 24733
Consulting Civil Engineer, Licensed Building
Surveyor
3. P.W.D Panel Engineer Appd.No Board of Eng. Processing No.
BOE/515-4(h)/2015/Dated : 27.10.2015
P.W.D – Chepauk – Chennai
Govt. of Tamil Nadu
4. Collector Panel Engineer Approved No. Coimbatore District –Panel of Registered Engineer
Reg No. 1/2016/C2 Govt of Tamil Nadu.
5. Number of years of experience And nature there of A total of 13 years experience in Construction
field (Designing and Execution of Multistoried
Framed Structures)



Er. P. ARUN PRASAD, B.Tech., C.Engg.,
M.I.E., F.I.V., M.I.C.A., M.ACCE.,
Approved Valuer, Consulting Civil Engineer & L.B.S.,
10/33 Ayyappan Kovil Street, Venkatesa Colony,
Pollachi - 642 001 Cell 98653 39919
COIMBATORE DISTRICT COLLECTOR'S
PANEL ENGINEER
GOVERNMENT OF TAMILNADU

(I) **STATEMENT ACCOMPANYING – FORM –A**

- | | |
|--|---|
| 1) Name of the Applicant | P.A International School
Chairman: P.Appukutty |
| 2) Door No. of the building
Location
Name of Place i.e corporation
Municipality/Union/Town | SF No. 98 Part & 99Part
Puliampatty Village
Puliampatty Village Panchayat |
| 3) Year of Construction | 2018 |
| 4) No. of Student & Staffs Accommodated | 1500 No.s |
| 5) Purpose for which the building is
Being used or proposed to be used. | School Building |
| 6) Purpose for which the building
Has either to been used | School Building |
| 7) Validity Period | 26.03.2023 to 25.03.2028 |
| 8) Details of construction of the
Building particulars of foundation
Soil, specification of the various
Parts under | |

Framed Structure Building

- | | |
|--------------------|--|
| a) Foundation | RCC Columns footing in 1:2:4 mix |
| b) Basement | RCC Plinth Beam in 1:2:4 mix |
| c) Super Structure | In Framed Structure Panel wall brick work |
| d) Floor and Roof | Granite Flooring & RCC Roof |
| e) No. of Storey | Ground Floor, First Floor, Second Floor &
Terrace Floor |
| f) Door and Window | Wooden Doors & UPVS Window |

Station: Pollachi
Date: 25.03.2023

Signature of the Certifying Engineer

**Er. P. ARUN PRASAD, B.Tech., C.Engg.,
M.I.E., F.I.V., M.I.C.A., MACCE.,**
Approved Valuer, Consulting Civil Engineer & L.B.S.,
10/133 Ayyappan Kovil Street, Venkatesa Colony,
Pollachi - 642 001 Cell 98653 39919
**COMBATORE DISTRICT COLLECTOR'S
PANEL ENGINEER
GOVERNMENT OF TAMILNADU**

9) Remarks

NIL

Build-up area details:

<u>Proposed Building Area Details</u>	
Area of Ground Floor Building	27410.42 Sq.ft
Area of First Floor Building	24174.87 Sq.ft
Area of Second Floor Building	13492.78 Sq.ft
Area of Terrace Floor Building	560.48 Sq.ft
TOTAL	65078.07 Sq.ft

Station: Pollachi

Date: 25.03.2023

Signature of the Certifying Engineer

Er. P. ARUN PRASAD, B.Tech., C.Engg.,
M.I.E., F.I.V., M.I.C.A., M.A.C.C.E.,
Approved Valuer, Consulting Civil Engineer & L.B.S.,
10/33, Ayyappan Kovil Street, Venkatesa Colony,
Pollachi - 642 001 Cell 98653 39919
COIMBATORE DISTRICT COLLECTOR'S
PANEL ENGINEER
GOVERNMENT OF TAMILNADU

(II)

FORM - B

- (I) (FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (4) OF SECTION 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING) ACT 1965. (TAMILNADU ACT 13 OF 1965) REFERRED TO IN RULE 4 OF THE TAMILNADU PUBLIC BUILDINGS (LICENSING) RULES 1966)

I certify that I Have inspected the building mentioned in the statement and furnished below its salient features.

FOUNDATION

- | | |
|--|-------------------------|
| a) Depth below ground level | 7'0" for wall |
| b) Nature of soil met with at | Soft Disintegrated Rock |
| c) Probable safe bearing capacity of the soil met with at foundation | 45 MT / M2 |
| d) Pressure at foundation | 19.5 Mt / M2 |

SUPER STRUCTURE:


- | | |
|--|---|
| a) Maximum stress in the most Critical section of masonry concrete | RCC Columns Footing in 1:2:4 mix
= 3.85 Mt/Sq.Ft |
| b) Nature of masonry and concrete and Its safe permissible stress | RCC Columns Footing in 1:2:4 mix
= 8 MT/Sq.Ft |

The structural soundness of the building has been verified by me with reference to I.S.I loading standards 875 (Latest Version) and other relevant Indian standard code of practice and I declare that the building is structurally sound to be used as a private building for the purpose noted in the statement.

Station: Pollachi

Date: 25.03.2023

Signature of the Certifying Engineer


Er. P. ARUN PRASAD, B.Tech., C.Engg.,
M.I.E., F.I.V., M.I.C.A., M.ACCE.,
Approved Valuer, Consulting Civil Engineer & L.B.S.,
10/33 Ayyappan Kovil Street, Venkatesa Colony,
Pollachi - 642 001 Cell 98653 39919
COIMBATORE DISTRICT COLLECTOR'S
PANEL ENGINEER
GOVERNMENT OF TAMILNADU

FORM - C
STATEMENT ACCOMPANYING
THE CERTIFICATE OF STRUCTURAL SOUNDNESS

- | | |
|---|--|
| 1) Location of the Building Door
Street No. & Name of the Place | S.F No. 98/Part & 99/Part
Puliampatty Village & Panchayat
Pollachi Taluk, Coimbatore |
| 2) Age of the Building
(Ground, First, Second, and
Terrace Floor) | 5 YEARS |
| 3) Number of Storey | GF. FF. SF & Terrace Floor |
| 4) Short description of Structures
Steel - RCC framed or Load
Bearing Masonry | RCC Colomns footing in 1:2:4 mix |
| 5) Purposed for which the building | School Building |
| 6) Remarks | NIL |

Station: Pollachi

Date: 25.03.2023

Signature of the Certifying Engineer



Er. P. ARUN PRASAD, B.Tech., C.Engg.,
M.I.E., F.I.V., M.I.C.A., MACCE.,
Approved Valuer, Consulting Civil Engineer & L.B.S.,
10/33 Ayyappan Kovil Street, Venkatesa Colony,
Pollachi - 642 001 Cell 98653 39919
COIMBATORE DISTRICT COLLECTOR'S
PANEL ENGINEER
GOVERNMENT OF TAMILNADU

FORM- D


III Form of Certificate of Structural Soundness Under sub – section (4) of section 4 of the Madras Public Buildings (Licensing) ACT 1965 (madras ACT 13 of 1965) referred to in rule 4 of the Madras Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the building mentioned in the statement below and I have satisfied myself that the building is structurally sound to be used as a private building for the purpose noted in the statement. The structural soundness of the building has been verified taking into account the Loading as per the Latest Indian standards 875.

Station: Pollachi

Date: 25.03.2023

Signature of the Certifying Engineer



Er. P. ARUN PRASAD, B.Tech., C.Engg.,
M.I.E., F.I.V., M.I.C.A., M.A.C.E.,
Approved Valuer, Consulting Civil Engineer & L.B.S.,
10/33 Ayyappan Kovil Street, Venkatesa Colony,
Pollachi - 642 001 Cell 98653 39919
COIMBATORE DISTRICT COLLECTOR'S
PANEL ENGINEER
GOVERNMENT OF TAMIL NADU

FORM – E


Form of report to be made to the competent Authority by Inspecting Authorities or Officers Under section 238 of the Madras Public Building (License Act 1965 Madras act 13 of referred to in rule 7 of the Madras Public Building (License) Rule 1966

1 Name of designation of inspecting Authority or officer appointed of having justification under act of law	Er. P.Arun Prasad, B.Tech. Civil, M.I.E., F.I.V., M.I.C.A., MACCE.,
2 Location Location of the Building Door Street No. & Name of the Place	S.F No. 98/Part & 99/Part Puliampatty Village & Panchayat Pollachi Taluk, Coimbatore
3 Date of Inspection	23.03.2023
4 Purpose of which the Building is used	School Building
5 Nature of defects Noticed	NIL
6 Suggestion for rectifying defects	NIL

Station: Pollachi

Date: 25.03.2023

Signature of the Certifying Engineer



Er. P. ARUN PRASAD, B.Tech., C.Engg.,
M.I.E., F.I.V., M.I.C.A., MACCE.,
Approved Valuer, Consulting Civil Engineer & L.B.S.,
10/33 Ayyappan Kovil Street, Venkatesa Colony,
Pollachi - 642 001 Cell 98653 39919
COIMBATORE DISTRICT COLLECTOR'S
PANEL ENGINEER
GOVERNMENT OF TAMILNADU

Proceedings of the District Collector, Coimbatore.
Present : Tmt.Archana Patnaik, I.A.S.,

Ref.No.10849/2015/C2

Dated: 24.06.2016.

Sub : Tamil Nadu Public Building Licensing act 1965 - inclusion of the name of Thiru.P.Arun Prasad in the panel of private practicing engineers under CLASS II category in Coimbatore district - approval of the board of engineers - orders issued - reg

- Ref : 1. Superintending Engineer, PWD Buildings(C&M), Coimbatore Lr.No.DB/DO2/F1142/2015/143M dated.12.08.2015.
2. Engineer-In-Chief, WRD, and Chief Engineer(General), PWD, Chennai lr.no.AEE/T1/AE/46411/2015 dated.03.11.2015.

ORDER-

The Engineer-In-Chief, WRD, and Chief Engineer(General), PWD, Chennai in the reference 2nd cited has stated that the board of engineers in its 515th Board of Engineering Meeting resolved and approved the name of Thiru.P.Arun Prasad (D.O.B.03.10.1982) for inclusion and registering in the panel of Private Practicing Engineer under Class II category (Buildings, the cost of which exceeds Rs.6.00 lakhs but not exceeding Rs.20.00 lakhs as per G.O.Ms.No.43, Municipal Administration & Water Supply (MA4) Department, dated.17.02.2011) in Coimbatore District.

Accordingly, the Thiru.P.Arun Prasad has been included in the panel of Private Practicing Engineer under Class II category (Buildings, the cost of which exceeds Rs.6.00 lakhs but not exceeding Rs.20.00 lakhs) in Coimbatore district and entered the name against Sl.no.01/2016 in the register of panel of Private Practicing Engineer maintained in this office.

Sd/-Archana patnaik
District Collector,
Coimbatore.

To

✓ Thiru.P.Arun Prasad,
No.20, Sri Abirami Aandal Nagar,
Near Kumaran Nagar,
Pollachi-642001

Copy to

1. Superintending Engineer, PWD Buildings(C&M), Coimbatore
2. Engineer-In-Chief, WRD, and Chief Engineer(General), PWD, Chennai

//By Order//

For District Collector

24/6/16